



GREENE COUNTY SANITARY ENGINEERING DEPARTMENT  
667 Dayton-Xenia Road, Xenia, OH 45385  
Phone (937) 562-7450 Fax (937) 562-7465

## INDUSTRIAL PRETREATMENT PROGRAM TEMPORARY DISCHARGE PERMIT

In accordance with all terms and conditions of the Greene County Office of Sanitary Engineering's Regulations and Specifications, adopted by Resolution No. 21-7-15-9 and also with any applicable provisions of federal or State law, or regulation; as a temporary discharger for the contribution of wastewater into the Greene County Sanitary Sewer, permission is hereby granted to:

---

Discharger

---

Address

---

Contact Person Telephone

---

Effective Date Termination Date

---

---

---

---

---

---

Description of Discharge Request

---

Signature of Authorized Person

No Discharger shall discharge wastewater containing concentrations of the following enumerated materials, exceeding the following values:

**Parameters**

<b>Flow Monitoring</b>	<b>Total/Continuous</b>
ph. min	6 S. U
ph. max	10 S. U
Temperature max	65 deg C
Total Suspended Solids	1000 mg/l
CBOD	1000 mg/l
Oil & Grease	200 mg/l

**Daily Maximum**

Arsenic (As)	1.0 mg/l
Cadmium (Cd)	1.0 mg/l
Copper (Cu)	1.0 mg/l
Cyanide (free) (CN)	3.6 mg/l
Lead (Pb)	3.0 mg/l
Mercury (Hg)	0.03 mg/l
Nickel (Ni)	6.0 mg/l
Selenium (Se)	1.0 mg/l
Silver (Ag)	1.3 mg/l
Zinc (Zn)	1.0 mg/l

**Wastewater Discharge Fees**

\$7.60.00/1000 gallons
\$ 4.50 IPP Admin fee

**Surcharges May Apply to Extra Strength Wastes**

CBOD and/or TSS between 300 and 1000 mg/l fall under an industrial user charge as follows:

300-500 mg/l CBOD and/or SS	\$15.46/1,000 gallons
500-1,000 mg/l CBOD and/or SS	\$ 30.93/1,000 gallons

**Conditions and Requirements**

GREENE COUNTY SANITARY ENGINEERING DEPARTMENT  
667 Dayton-Xenia Road, Xenia, OH 45385  
Phone (937) 562-7450 Fax (937) 562-7465

- All measurements, tests or analyses of the characteristics of waters and wastes, to which reference is made in this ordinance, shall be determined in accordance with the techniques prescribed in 40 CFR Part 136 and amendments thereto, unless otherwise specified in an applicable categorical Pretreatment Standard. If 40 CFR Part 136 does not contain sampling or analytical techniques for the pollutant in question, or where the EPA determines that the Part 136 sampling and analytical techniques are inappropriate for the pollutant in question, sampling and analyses shall be performed accordance with the latest edition of "Standard Methods for the Examination of Water and Waste Water" published by the American Health Association.
- Samples shall be a grab and analyzed prior to discharge and approved by Greene County Sanitary Engineering to ensure compliance.
- Discharge event shall be applied at an acceptable flow rate that is agreeable to the County and discharger.
- All dewatering, sampling and analyses shall be in accordance with the Greene County Sanitary Engineering Local Limits.
- All discharge fees will be charged in the amounts as recorded in the Greene County Sanitary Engineering Regulations Rates and Fees effective February 1<sup>st</sup> 2019.

This temporary discharge permit is approved and granted in accordance with the Greene County Regulations and in conformity with Description of Discharge Request and together with the conditions and requirements.

---

Greene County Sanitary Engineering Department

Date